STREET ADDRESS:

MAILING ADDRESS:

Lazarus Government Center 122 S. Front Street Columbus, Ohio 43215 TELE: (614) 644-3020 FAX: (614) 624-3189CT 30 PM 12: 0

P.O. Box 1049 Columbus, OH 43216-1049

October 26, 2006

Re: Washington County

Application No. 429534 ws Community Water System

Little Hocking Water & Sewer Association PWS - 8400212 (PWS ID)

Detail Plans of A Proposed Granular Activated Carbon (GAC)

Water Treatment Plant

Plans Received May 08, 2006

Revised Plans Received May 5, 2006

From October 12, 2006

Little Hocking Water and Sewer Association P.O. Box 188 Little Hocking, OH 45742

Ladies and Gentlemen:

The Ohio Environmental Protection Agency has reviewed the enclosed plans submitted pursuant to Ohio Revised Code Sections 6109.07 et. seq., or accepted the certification of plan review by an authorized professional engineer pursuant to a contract therefore. These plans are approved subject to the condition of compliance with all applicable laws, rules, regulations, and standards. The applicant is responsible for obtaining all other necessary approvals, waivers or releases required by state, federal or local law prior to implementing this plan. Further, all construction must be supervised by a registered engineer, if required by law, or expert qualified in such work.

The enclosed report or project summary sheet(s) contains a description of the facilities approved which may include information regarding approved operating rates, capacities, and requirements, and is incorporated herein.

This approval shall become void five years from the date of this letter unless the facilities are constructed as proposed by that date. By accepting this approval, the applicant acknowledges that this deadline shall not be considered or construed as extending or having any effect whatsoever on any compliance schedule or deadline set forth in any administrative or court order issued to or binding upon the applicant, and the applicant shall abide by such compliance schedules or deadlines to avoid the initiation of additional legal action by the Ohio Environmental Protection Agency.

Lead solder and flux that exceeds 0.2 percent lead content and any pipe or pipe fitting that exceeds an 8 percent lead content shall not be used in the installation of the proposed facilities.

The proposed facility may be constructed only in accordance with plans approved by the director of the Ohio Environmental Protection Agency. There may be no deviation from the approved plans without the express, written approval of the agency. Any deviation from the approved plans or the above conditions may lead to sanctions and penalties provided under Ohio law. Approval of these plans does not constitute an assurance that the proposed facilities will operate in compliance with all Ohio laws and regulations. Additional facilities shall be installed upon orders of the Ohio Environmental Protection Agency if the proposed facilities prove to be inadequate or cannot meet applicable standards.

DOCUMENT 14

EPA 00100

Bob Taft, Governor Bruce Johnson, Lieutenant Governor Joseph P. Koncelfk, Director



Little Hocking Water and Sewer Association October 26, 2006 Page Two

Should there be any questions regarding the requirements, meaning, or interpretation of any of the above which we may clarify, please contact the Division of Drinking and Ground Waters, Southeast District Office, Ohio Environmental Protection Agency.

You are hereby notified that this action of the Director is final and may be appealed to the Environmental Review Appeals Commission pursuant to Section 3745.04 of the Ohio Revised Code. The appeal must be in writing and set forth the action complained of and the grounds upon which the appeal is based. The appeal must be filed with the Commission within thirty (30) days after notice of the Director's action. The appeal must be accompanied by a filing fee of \$70.00 which the Commission, in its discretion, may reduce if by affidavit you demonstrate that payment of the full amount of the fee would cause extreme hardship. Notice of the filing of the appeal shall be filed with the Director within three (3) days of filing with the Commission. Ohio EPA requests that a copy of the appeal be served upon the Ohio Attorney General's Office, Environmental Enforcement Section. An appeal may be filed with the Environmental Review Appeals Commission at the following address:

Environmental Review Appeals Commission 309 South Fourth Street, Room 222 Columbus, OH 43215

Sincer

oseph P. Koncelik

Director

JPK/fbs

cc: Southeast District Office
Division of Drinking and Ground Waters, Central Office
URS Corporation - Wilmington
Washington County Health Department

hP Konell